

Meeting Minutes

Meeting Room	9601 Ridgehaven Ct. Ste. 220, 2 nd Fl Training Room
Date	3/1/2018
Time	11:30am-1:00pm
Meeting Facilitator	Chad Gustine (City of San Diego)
Meeting Attendees	()Amir Amiri, ()Mark Chrysler, (X)Lee Edging, ()Martin Montessoro, ()Bao Phan, (X)John Alaimo City of San Diego, (X)Aaron Astrum, City of La Mesa, (X)David Corrales, ()Bob Nagle, (X)Richard Lambert,, County of San Diego, ()Gene Koshiol, City of El Cajon, ()Eric Jenson, Esgil Corp., ()Steve Jones, City of Oceanside, (X)Israel Juarez, (X)Tiffany Maycumber, SDG&E, ()Paul Donaldson, City of San Marcos, ()John LeVey, City of Escondido, ()Luis Sainz, City of National City, ()Scott Humphry, City of Chula Vista,

Today's Agenda

S. No.	Topics	Action Points	Owner
1	TSPB	For use in single family dwellings. Permitted uses: 1) construction power 2) To accommodate the transfer of ownership from contractor/construction to homeowner.	Tiffany
3	Manufactured Home's with built-in PV Systems. Who will release the PV System?	AHJ will release PV System to the Utility upon approving the electrical service/supply.	Tiffany
4			
5	Art 310.15(B)(7)	Careful determination is required when new systems such as, EV Charging Systems Art 625, and Energy Storage Systems Art 706 are being added to existing systems which were installed with specific code limitations such as: Art 310.15(B)(7)	Aaron
6			
7	IAEI question of the month	Can a receptacle be installed directly behind a TV mounted to the wall? Yes, see 2014 NEC Art. 422.33(A) and 422.31(A) note: There is a slight change to 422.31(A) in the 2017 NEC which requires the breaker to be lockable when not within sight.	Chad

		Solar Ready Panels- Can the location identified as “Auxiliary Energy Source” supply additional loads? Per UL, supplying additional loads does not void the listing of the equipment.	
9	Good of the order	Can more than one feeder be installed to a building? 2014 NEC art 225.30. A building or other structure that is served by a branch circuit or feeder on the load side of a service disconnecting means shall be supplied by only one feeder or branch circuit unless permitted in 225.30(A) through (E)	Tiffany
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			